



**District Level Water Testing Laboratory**  
**(Uttar Pradesh Jal Nigam, Pilibhit)**  
*Address: Office of Executive Engineer, Construction Division,  
U.P. Jal Nigam in front of district secondary Hospital, Tanakpur road, Pilibhit, Pin- 242521*



**TEST REPORT**

Repl. No. 9304

Date: 01-01-2025

**Customer Details**

Office Name and Address: Manager Lucky Children Junior High School, Puranpur, Pilibhit

Ref Letter No & Date: Application by Customer date- 30-12-2024

**Sample Description**

District	Pilibhit	Block	Puranpur
Gram Panchayat/Nagar Panchayat	Dehat Kshetra	Village/Ward No.	Dehat Kshetra
Habitation	Pilibhit Road Purapur	Location	Lucky Children Junior High School
Water Source	RO Water	Sample Code	PHL 24 12 9304
Date & Time of Sample Collection	31-12-2024 02:00PM	Sample Collector Name	Aadarsh
Receiving Date & Time	31-12-2024 03:30PM	Sample Receiver	Sanjeev Kumar
Water Sample Type	Drinking Water	Quantity of Sample	1000ml
Analysis Date	31-12-2024 to 01-01-2025		

**Technical Data of Analysis**

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Chloride	7.99	mg/l	250	1000	IS 3025 (Part 32) : 2019
2	Fluoride	0.080	mg/l	1	1.5	APHA 24th Edition 4500-F Method C (Electrode Method): 2023
3	Iron	0.081	mg/l	1	No relaxation	IS 3025 (Part 53) : 2019
4	Nitrate	2.18	mg/l	45	No relaxation	APHA 24th Edition 4500-NO <sub>3</sub> Method B (UV Screening Method):2023
5	pH	7.38	NA	6.5-8.5	No relaxation	IS 3025 (Part 11) : 2022
6	Sulphate	6.99	mg/l	200	400	APHA 24th Edition 4500-SO <sub>4</sub> <sup>2-</sup> Method E (Turbidimetric Method) : 2023
7	TDS	112	mg/l	500	2000	IS 3025 (Part 16) : 2023
8	Total Alkalinity	95	mg/l	200	600	IS 3025 (Part 23) : 2023
9	Total Hardness	70	mg/l	200	600	IS 3025 (Part 21) : 2019
10	Turbidity	2.71	NTU	1	5	IS 3025 (Part 19) : 2023
11	Total Coliform	Absent	N/A	No relaxation	-	By H2S Vials

Principal  
Lucky Children J H School  
Puranpur (Pilibhit)

Manager  
Lucky Children Jr. High School  
Pilibhit Road, Puranpur (Pilibhit)

Note 1: This Certificate refers only to the particular sample(s) submitted for testing

- 1. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has
- 2. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements
- 3. Sample will be stored up to 2-3 days (in case of non perishable items only) from the date of issue of test reports unless
- 4. \*Indicates parameters that are not NABL accredited

Authorized Signatory

Ansh Kumar

Laboratory Manager

U.S. Jal Piggan

PILIBHIT

End of the Report

Principal

Lucky Children J H School  
Puranpur (Pilibhit)

Manager

Lucky Children Jr. High School  
Pilibhit Road, Puranpur (Pilibhit)

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 9304

Dated: 01/01/2024

It is certified that an inspection team headed by Anuj Kumar Lab. chemist  
 (Name of Officers with designation) from U.P. Jal Nigam (Rural) Pilibhit  
 (Name of Department/ Office) inspected the Lucky children junior High school  
 (Name & Address of the school) on 31/12/2023 (date of inspection) and found that the  
Lucky children junior High school (Name of school) has safe drinking water  
 facilities for the students and members of staff of the institution and is maintaining the hygienic  
 sanitation condition in the school building & the campus as per norms prescribed by the Central/  
 State/ U.T. Govt.

The above is valid for a period of 6 month

Signature with Seal: YName : Manish GangwarDesignation : Executive Engineer

Name &amp; Address of the Office / Department : .....

To

Lucky children junior High school  
Pilibhit Road Puranpur

(Name &amp; Address of the Institution)



\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]  
 Principal  
 Lucky Children J H School  
 Puranpur (Pilibhit)